



B	Giðleiki rcftauga mm ²	Cu 3x2,5	Cu 3x2,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5	Cu 4x1,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5	Cu 3x1,5		
	Afl kW	2,4	2	0,06	0,25	0,13	0,25	0,1-0,3	0,24	0,24	0,24	0,12	0,2	0,04		
	Straumur A	12,1	10,1	0,3	1,3	0,7	1,3	0,5-1,6	1,2	1,2	1,2	0,6	1	0,2		
	Kapainúmer	301W31	301W32	301W33	301W34	301W35	301W36	301W37	301W38	301W39	301W40	301W41	301W42	301W43	301W44	
	Raðtengjanúmer	301X31 M2,N,PE	301X32 M3,N,PE	301X33 M1,N,PE	301X34 M1,N,PE	301X35 M1,N,PE	301X36 M1,N,PE	301X37 L1,M1,N,PE	301X38 M1,N,PE	301X39 M1,N,PE	301X40 M1,N,PE	301X41 M1,N,PE	301X42 M1,N,PE	301X43 M1,N,PE	301X44 L1,N,PE	501X1 L-10,N,PE

A	Texti	LJÓŠ NIDRI SAL	LJÓŠ UPPI SAL	ÚTLJÓŠ VID INNGÖNGUDYR	ÚTLJÓŠ VD MOTTÖKUGRYFUJ	ÚTLJÓŠ VID MÖTÖKU A SUKRAHURSLU	ÚTLJÓŠ STORA HURD NIDRI	RATJYSING I SAL OG NEYDARLYSING	LJÓŠ TÖFLUHERBERGI	LJÓŠ STJÖRNHERBERGI	LJÓŠ VERKSTÆÐI	LJÓŠ GANGUR VID BÄD	LJÓŠ BÄD	LJÓŠ WC	HINDRINARLJÓŠ FLUGMALASTJÖRNAR A RETYKRAFT	STYRING FYRIR LJÓŠ
---	-------	---------------------	--------------------	---------------------------	----------------------------	---------------------------------------	----------------------------	------------------------------------	-----------------------	------------------------	-------------------	------------------------	-------------	------------	--	-----------------------



RÁÐVÍS HÖNNUN
 Grensásvegi 7, 108 Reykjavík
 Sími 91-35553 Fax 91-687301

Verk: VESTMANNAEYJABÆR-SORPÆRENISLUSTÖÐ
 RAFLAGNIR
 AÐALTAFLA TA1

Teikn. nr.: 1.301
 M.kv.: ~

Verk nr.: VB920631
 Breyting: