


SJÁ TEIKNINGU E23.5.101

DÆLUKJALLARI

SKÝRINGAR:

① RAFBÚNAÐUR Í RÝMI SKAL VERA IP44

-	-	-	
-	-	-	
-	-	-	
B	2017-06-20	Færsla á rofum og skýringar	EKD
A	2017-04-06	VERKTEIKNING	EKD
ÚT	DAGS.	BREYTING	SAMÞ.



HANNAÐ: SLJ RYNI: BIH SAMÞ.: EKD  
VERKFRANG: 07257

**HS VEITUR HF**  
Brekkestig 36  
260 Reykjanesbær  
Sími: 422 5200  
Fax: 421 4727  
Netfang: hs@hs.is

**HITAVEITA VESTMANNNAEYJUM**  
Varmadæla  
Lágspennukerfi  
Grunnmynd, dælujallari

MRV:	1:50	DAGS:	2016-12-19
KKS FERLI:	-		
TEIKN NR.:	E23.5.001	ÚTG.:	B
SAMÞYKKT AF BYGGINGARFULLTRÚA	[Signature]		