


SKÝRINGAR:

- ① TENGLAKASSI, H=1100mm.
- ② BRÚKRANI, H=5000, -Q12.
- ③ PILOFN Á VEGG, 1500W.
- ④ RAFBÓNAÐUR Í BORHOLUHÓSI SKAL VERA A.M.K. IP44.

-	-	-
-	-	-
-	-	-
B	2017-06-20	Breyting á númeringu EKD
A	2017-04-06	VERKTEIKNING EKD
ÚT. DAGS.	BREYTING	SAMB.



HANNAÐ: SLJ RYNI: BIH SAMB.: EKD
VERKFAANG: 07257



Brekkustíg 36
260 Reykjanæsbær
Sími: 422 5200
Fax: 421 4727
Netfang: hs@hs.is

HITAVEITA VESTMANNAEYJUM
Varmadæla

Lágspennukerfi
Grunnmynd, 1. hæð

MKV: 1:50 DAGS: 2016-12-19

KKS FERLI: -

TEIKN.NR.: E23.5.102 ÚTG.: B

SAMÞYKKT AF BYGGINGARFULLTRÚA
Gyrdur Guðmundsson 2405654299

1. HÆÐ

6

7

8

9

10

11

12

13